

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 25

Dated: 06/03/2024

It is certified that an inspection team headed by Neeraj, Assistant Engineer from PH Sub – Division, Sasaram inspected the DAV Public School, Hansraj Nagar, Admapur, Sasaram, Rohtas on 06/03/2024 and on the basis of Water Test Report (Attached) bearing no NIL dated 28/02/2024 of PHED Lab, Sasaram certified that the DAV Public School, Hansraj Nagar, Admapur, Sasaram, Rohtas has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 06/03/2025.

Signature with seal :

Name :

Designation :

Neeraj

NIRAJ

A.E

अवर प्रमण्डल पदाधिकारी
लोक स्टा० अवर प्रमण्डल
सासाराम

To
DAV Public School,
Hansraj Nagar, Admapur, Sasaram

Manager
D.A.V. Public School
Hansraj Nagar, Admapur
Sasaram, Rohtas

Principal
D. A. V. Public School
Hansraj Nagar, Admapur
Sasaram, Rohtas

Office of the Executive Engineer
Public Health Engineering Department, Sasaram (Rohtas)

Divisional Laboratory:- Sasaram

(Values In mg /Lit. except pH. Otherwise mentioned)

Zone :- Patna						Division Name: SASARAM														Date:28/02/2024	
Sl. No.	Block	Panchayat	Village	Name of Habitation/ Ward No.	Location of Source	Parameters															
						pH	Turb.	Ec	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO3	SO4	F	AS	Total Coll.	
1	Sasaram	Nagar Nigam Sasaram	Hansraj Nagar Admapur	D.A.V. School Hansraj Nagar Admpur, Sasaram	D.A.V. School Hansraj Nagar Admapur, Sasaram	6.94	<0.5	446	290	194	58.8	35.3	23	230	0.1	Nil	5	0.6	NT	Negative	
Desirable Limit						6.5-8.5	1		500	200	75.0	30.00	250	200	1.0	45	200	1	0.01		
Drinking Water Specification (Second Revision) IS 10500 /2012 Permissible limit in absence of alternate source						NR	5.0 NTU		2000	600	200	100	1000	600	NR	NR	400	1.5	NR		

Note:- BDL (Below Detection Limit), NT (Not Tested) & NR (NO Relaxation)

Note:- Sample collected by - School Staff

Daya Maankant
 05-03-2024
Assit.Chemist
P.H. Div, Sasaram

R Kumar
 05/03/24
Chemist
P.H. Div, Sasaram

[Signature]
Manager
 D.A.V. Public School
 Hansraj Nagar, Admapur
 Sasaram, Rohtas

[Signature]
Principal
 D. A. V. Public School
 Hansraj Nagar, Admapur
 Sasaram, Rohtas